

720 S. Main St. Findlay, OH. 45840

Emergency Phone 911
 Base Station Phone 424-7127
 Fax 424-7849
 Cell 421-6673
 Fire Chief - Tom Lonyo

Unit Number	Engine 1	Ladder 1	26	46	22	20	21
Type of Apparatus	Pumper	85' Aerial	Utility	Equip. Trlr.	Batt. Chief	Chief	Asst. Chief
Year	1997	1988	1978	1989	1999	1993	1997
Apparatus Manufacturer	Custom Fire	Custom Fire		Wells Cargo			
Make of Chassis	HME	Pemfab	Dodge		Chevrolet	Ford	Plymouth
Pump Capacity (GPM)	1500	1500					
Pump Position	Midship	Midship					
Booster Tank (Gal.)	1000	300					
5" Hose (Ft.)	1200	1100					
4.5" Hose (Ft.)							
4" Hose (Ft.)							
3" Hose (Ft.)							
3" Hose - Preconn. (Ft.)							
2.5" Hose (Ft.)	600	800					
2.5" Hose - Preconn. (Ft.)							
1.75" Hose		400					
1.5" Hose (Ft.)	400						
1.5" Hose - Preconn. (Ft.)	350						
Generator (Watts)	7000	3500		4400			
Lights (500 Watts+)	7	1					
Portable pump (GPM)							
Foam Eductor (GPM)	100			60			
Foam Concentrate (Gal.)	70		75				
SCBA's	6	4		7			
Extra Air Bottles	9	9		20			
Radio Equipment	800 mhz	800 mhz	800 mhz	800 mhz	800 mhz	800 mhz	800 mhz

Other Equipment:

Thermal Imaging Camera	1	Computers	Desktops
Air Comp. & Cascade	1	Port. Radios	15
Port. Cascade on Unit 46	1	MSA CGI	1
Multi-gas Monitoring	1	Entry Saws	2
Water Curtain	2	Chain Saws	1
Hydrant Manifolds	2	Hi-X Eductor	1
PPV Fan - Gas	1		

High angle and confined space rescue equipment on Unit 26

Extra foam concentrate (AFFF & high expansion)

Extra hose: 1800' - 2.5 & 1800' - 1.5"

Hydraulic extrication equipment

Assorted absorbant materials on Unit 46

Note: Hydrants have Findlay thread on steamer and 2.5" are NST.

FINDLAY STATION #2 (North)

900

WPKV 206

N. Main St. Findlay, OH. 45840

Emergency Phone	911
Base Station Phone	422-4246
Fax	424-7849
Cell	421-6673
Fire Chief - Tom Lonyo	

Unit Number	Engine 2	30
Type of Apparatus	Pumper	Utility
Year	1984	1993
Apparatus Manufacturer	Sutphen	Chevrolet
Make of Chassis	Sutphen	S-10
Pump Capacity (GPM)	1500	
Pump Position	Midship	
Booster Tank (Gal.)	500	
5" Hose (Ft.)	1150	
4.5" Hose (Ft.)		
4" Hose (Ft.)		
3" Hose (Ft.)		
3" Hose - Preconn. (Ft.)		
2.5" Hose (Ft.)	1200	
2.5" Hose - Preconn. (Ft.)		
1.75" Hose		
1.5" Hose (Ft.)	400	
1.5" Hose - Preconn. (Ft.)	350	
Generator (Watts)	3500	
Lights (500 Watts+)	4	
Portable pump (GPM)		
Foam Eductor (GPM)	95	
Foam Concentrate (Gal.)	10	
SCBA's	5	
Extra Air Bottles	6	
Radio Equipment	800 mhz	800 mhz

Other Equipment:

Thermal Imaging Camera	Computers	Desktop
Air Comp. & Cascade	Port. Radios	4
Port. Cascade on Unit 46	MSA CGI	
Multi-gas Monitoring	Entry Saws	1
Water Curtain	Chain Saws	
Hydrant Manifolds	Hi-X Eductor	
PPV Fan - Gas		
Extra hose: 2900' - 2.5 & 1000' - 1.5"		

Note: Hydrants have Findlay thread on steamer and 2.5" are NST.

Tiffin Ave. Findlay, OH. 45840

Emergency Phone 911
 Base Station Phone 422-0979
 Fax 424-7849
 Cell 421-6673
 Fire Chief - Tom Lonyo

Unit Number	Engine 3	29	Water Rescue
Type of Apparatus	Pumper	Utility	14' Grumman Boat
Year	1978	1993	w/25 hp OB
Apparatus Manufacturer	Sutphen	Ford	
Make of Chassis	Sutphen	F-250	Zodiac
Pump Capacity (GPM)	1500		w/15 hp OB
Pump Position	Midship		
Booster Tank (Gal.)	500		Res-Q-Deck
5" Hose (Ft.)	1000		(Pontoon)
4.5" Hose (Ft.)			w/19.8 hp OB
4" Hose (Ft.)			
3" Hose (Ft.)			Cold water
3" Hose - Preconn. (Ft.)			rescue suits
2.5" Hose (Ft.)	600		
2.5" Hose - Preconn. (Ft.)			PFD's
1.75" Hose			
1.5" Hose (Ft.)	400		"Rescue Alive"
1.5" Hose - Preconn. (Ft.)	350		Ice rescue sled
Generator (Watts)	7000		
Lights (500 Watts+)	5		
Portable pump (GPM)			
Foam Eductor (GPM)	95		
Foam Concentrate (Gal.)	75		
SCBA's	5		
Extra Air Bottles	9		
Radio Equipment	800 mhz	800 mhz	

Other Equipment:

Thermal Imaging Camera	1	Computers	Desktop
Air Comp. & Cascade		Port. Radios	4
Port. Cascade on Unit 46		MSA CGI	
Multi-gas Monitoring		Entry Saws	1
Water Curtain		Chain Saws	
Hydrant Manifolds	1	Hi-X Eductor	
PPV Fan - Gas	1		
Extra hose: 2900' - 2.5 & 1000' - 1.5"			
Telescopic Light Tower on Engine 3			

Note: Hydrants have Findlay thread on steamer and 2.5" are NST.

FINDLAY STATION #4 (Far East)**900**

WPKV 206

Co. Rd. 236 Findlay, OH. 45840

Emergency Phone 911
 Base Station Phone 424-7414
 Fax 424-7849
 Cell 421-6673
 Fire Chief - Tom Lonyo

Unit Number	Engine 4	Ladder 4	Engine 5	23
Type of Apparatus	Pumper	85' Snorkel	Pumper	Utility
Year	1996	2000	1980	1993
Apparatus Manufacturer	Custom Fire	Custom Fire	Seagrave	Chevrolet
Make of Chassis	HME	HME	Seagrave	S-10 Blazer
Pump Capacity (GPM)	1500	1500	1500	
Pump Position	Midship	Midship	Midship	
Booster Tank (Gal.)	500	300	300	
5" Hose (Ft.)	1000	1000	900	
4.5" Hose (Ft.)				
4" Hose (Ft.)				
3" Hose (Ft.)				
3" Hose - Preconn. (Ft.)				
2.5" Hose (Ft.)	600	800	800	
2.5" Hose - Preconn. (Ft.)				
1.75" Hose		400		
1.5" Hose (Ft.)	400		400	
1.5" Hose - Preconn. (Ft.)	350		350	
Generator (Watts)	7000	8500	3500	
Lights (500 Watts+)	5	3	3	
Portable pump (GPM)				
Foam Eductor (GPM)	95	150	95	
Foam Concentrate (Gal.)	15		5	
SCBA's	6	5	5	
Extra Air Bottles	9	5	5	
Radio Equipment	800 mhz	800 mhz	800 mhz	

Other Equipment:

Thermal Imaging Camera		Computers	Desktop
Air Comp. & Cascade		Port. Radios	11
Port. Cascade on Unit 46		MSA CGI	
Multi-gas Monitoring		Entry Saws	2
Water Curtain		Chain Saws	1
Hydrant Manifolds	2	Hi-X Eductor	
PPV Fan - Gas	1		
Extra hose: 2000' - 2.5 & 1000' - 1.5"			
Portable generator (3500w) on Ladder 4			
Telescopic Light Tower on Engine 4			

Note: Hydrants have Findlay thread on steamer and 2.5" are NST.